# Data Sheet | Item Number: 224-112

2-conductor lighting connector; push-button on lighting side; Lighting side: for all conductor types; Inst. side: for solid conductors; 224 Series; max. 2.5 mm²; Surrounding air temperature: max 60°C; 2,50 mm²; white




https://www.wago.com/224-112





Color: white



Dimensions in mm

Notes	
Safety information	in grounded power lines

#### Electrical data EN 60664 Ratings per Ш Ш Overvoltage category Ш Pollution degree 3 2 2 400 V Nominal voltage Rated surge voltage 4 kV Rated current 24 A



			·	
Connection data				
Connection points	3	Connection 1		
Total number of potentials 1	1	Connection type 1	Installation side	
		Connection technology	PUSH WIRE®	
		Number of connection points	2	
		Actuation type	Push-in	
		Connectable conductor materials	Copper Aluminum	
		Connectable conductor materials (note)	Terminating Aluminum Conductors (Not for use in North America) WAGO spring clamp terminal blocks are suitable for solid aluminum conductors up to 4 mm²/12 AWG if WAGO "Alu-Plus" Contact Paste 249-130 is used for termination.	
			"Alu-Plus" Contact Paste Advantages:	
			<ul> <li>Automatically destroys the oxide film during clamping.</li> <li>Prevents fresh oxidation at the clamping point.</li> <li>Prevents electrolytic corrosion between aluminum and copper conductors (in the same terminal block).</li> <li>Provides long-term protection against corrosion.</li> </ul>	
			Using terminal blocks with CAGE CLAMP® Spring Pressure Connection Technology, aluminum conductors must first be cleaned with a blade and then immediately be inserted into the clamping units filled with "Alu-Plus" Contact Paste.	
			For spring clamp connections with PUSH WIRE® connection technology, <b>WAGO recommends that the aluminum conductor first be cleaned</b> and then immediately inserted into the clamping unit filled with "Alu-Plus" contact paste.	
			It is also possible to apply WAGO "Alu- Plus" <b>additionally</b> on the whole surface of the aluminum conductor before termi- nation.	
			Please note that the nominal currents must be adapted to the reduced conduc- tivity of the aluminum conductors:: 2.5 mm <sup>2</sup> = 16 A 4 mm <sup>2</sup> = 22 A	
		Solid conductor	1 2.5 mm² / 16 14 AWG	
		Strip length	9 11 mm / 0.35 0.43 inches	
		Wiring direction	Side-entry wiring	

Connection 2	
Connection type 2	Lighting side
Connection technology 2	CAGE CLAMP®
Number of connection points 2	1
Solid conductor 2	0.5 2.5 mm² / 20 14 AWG
Fine-stranded conductor 2	0.5 2.5 mm² / 20 16 AWG

# Data Sheet | Item Number: 224-112

https://www.wago.com/224-112



#### Physical data Width 9.5 mm / 0.374 inches Height 15.5 mm / 0.61 inches Depth 20.5 mm / 0.807 inches

Material data	
Note (material data)	
	<u>Information on material specifications can be found here</u>
Color	white
Fire load	0.047 MJ
Weight	2.1 g

Environmental requirements	
Ambient temperature (operation)	+60 °C
Continuous operating temperature	105 ℃

Environmental Product Compliance	
RoHS Compliance Status	Compliant, No Exemption

# Approvals / Certificates

# General approvals











		_		
	/		1	
1	ν	D	E	•

Approval	Standard	Certificate Name
CSA DEKRA Certification B.V.	C22.2	1053495
UL UL International Germany GmbH	UL 486C	E69654
UL UL International Germany GmbH	EN 60998	CCA-2617-A1
UL UL International Germany GmbH	EN 60998	D-05895-A1 (EN60998-1 EN60998-2-2)
VDE VDE Prüf- und Zertifizie- rungsinstitut	EN 60998	40022792

# Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-
UK-Declaration of Conformity WAGO GmbH & Co. KG	-	-

# Approvals for marine applications









Approval	Standard	Certificate Name
ABS American Bureau of Ship- ping	-	18-HG1755093-PDA
BV Bureau Veritas S.A.	EN 60998	11914/D0 BV
DNV GL Det Norske Veritas, Ger- manischer Lloyd	EN 60998	TAE000015T
LR Lloyds Register	EN 60998	LR22207029TA



#### 1 Compatible Products

## 1.1 Optional Accessories

#### 1.1.1 Tool

## 1.1.1.1 "Alu-Plus" contact paste



Item No.: 249-130

Syringe; Contents: 20 ml Alu-Plus contact paste

#### **Installation Notes**

#### Conductor termination







Strip conductor to 9 ... 11 mm (0.35 ... 0.43 inch).

# Conductor termination





To connect: Press button fully, insert stripped conductor into square entry and release.



To remove: Press button and withdraw conductor.

#### Conductor termination





To connect: Insert stripped solid conductor into circular entry and push until it hits the backstop.



To remove: Hold conductor to be removed and twist alternately left and right while slightly pulling the connector.

## Testing



Testing via separate test ports.



Page 5/5 Version 11.01.2024